

Gustaaf Popestraat 49  
9300 Aalst  
Info@corcon.be  
BTW: 0471 957 458  
RPR Dendermonde

tel. 053 78 34 85  
fax. 053 70 88 62  
www.corcon.be  
Fortis: 293-0188486-70  
IBAN: BE 60 293-0188486-70  
BIC: GEBABEBB

## Prototype approval certificate no. CP0622/1655-HCC001

### APPLICANT

RIKUTEC Iberia S.A.U.  
Póligono Industrial de Lantarón, parcelas 15 y 16  
SP-01213 Comunion, Álava

### MANUFACTURER

RIKUTEC Iberia S.A.U.  
Póligono Industrial de Lantarón, parcelas 15 y 16  
SP-01213 Comunion, Álava

### Tank Type

Above ground single wall  
Build in HDPE  
Blow-moulding principle

### Conformity Evaluation According To

Vlarem II (01/10/2019) Article 5.17.4.3.3 and Annex 5.17.2  
Code of good practice based on:  
NBN EN 13341:2005+A1:2011  
DIBt-Zulassung Z-40.21-212:2014

### Scope

Vlarem II (01/10/2019)  
Subsection 5.17.4.3 Storage of dangerous liquids in above ground storage tanks

### Certificate limitation

Storage of dangerous liquids other than domestic heating oils and diesel fuels  
EUROLENTZ type 750 RELB/TELB 66 – 1000 RELH/TELH 66  
1000 RELB/TELB 72 – 1500 REL/TEL 72 – 2000 REL/TEL 72 – 2500 REL/TEL 88  
Raw material only Alcludia 49070 UV from Repsol Quimica S.A.  
Indoor installation (no installation in explosion zones 0 and 1)  
Life expectancy statement by the manufacturer of 25 years

**THIS CERTIFICATE IS ONLY VALID WHEN ACCOMPANIED BY  
THE DECLARATION OF CONFORMITY BY THE MANUFACTURER  
Accompanying pages 2 till 20 available for consultation by the manufacturer**

Certificate valid from 24/05/2022 till 23/05/2027

Francine Van Moorter

Milieudeskundige 2002/HCC001  
Corrosiedeskundige 2002/KCC001

Julien Van Barel

Milieudeskundige 2012/HJulienVanBarel  
Corrosiedeskundige 2012/KJulienVanBarel